



**NOTES:**

1. ALL HYDRANTS SHALL BE MUELLER SUPER CENTURION 250 A-423 OR APPROVED EQUAL WITH 5- 1/4" MAIN VALVE, (2) 2 - 1/2" HOSE NOZZLE, (1) - 4-1/2" PUMPER NOZZLE ALL NATIONAL STANDARD, 1 1/2" PENTAGON, OPEN LEFT (COUNTER-CLOCKWISE) 6' BURY.
2. PROVIDE 6" N.R.S. RESILIENT WEDGE GATE VALVE AND VALVE BOX WITH "WATER" CAST INTO THE LID, MUELLER A-2360-16 OPEN LEFT.
3. ZINC CAPS WILL BE REQUIRED ON ALL MECHANICAL JOINT FITTINGS.

<b>Village of Mount Prospect</b>	
Public Works Department	
1700 W. Central Rd.	
<b>FIRE HYDRANT DETAIL</b>	
<b>Last Revised:</b>	<b>8-09</b>