



Village of Mount Prospect
Community Development Department
50 S. Emerson Street
Mount Prospect, Illinois 60056
Phone: (847) 870-5675

Email: building@mountprospect.org

Deck Supplement

PERMIT SUBMITTAL REQUIREMENTS:

- Completed and signed permit application by applicant & property owner.
- Submit 4 sets of plans indicate framing sizes and spacing, pier locations, and details on railings and stairs. [Free plans can be obtained from kiosks in various Home Center Stores] Refer to attached deck tables and diagrams for more information.
- Submit 4 copies of the Plat of Survey with the location of the deck indicated in ink.
- Indicate the overall dimensions and the distances from the lot lines and other buildings on the property. Decks are not allowed in easements.
- Provide a copy of the owner signed contract/proposal if a contractor is involved.

DECK REGULATIONS (Sec. 14.306, Chapter 14)

- Overhead electrical service lines must be a minimum of 10' clear vertically from the deck floor and not within reach horizontally.
- Pier holes shall be a minimum of 42" deep and sized according to the provided chart.
- The minimum post size is 4" x 4" when beams bear on top. If a deck is over 8' above grade, or if beams are notched into the posts, then posts shall be a minimum of 6"x6". In addition, posts are required to support each stair stringer.
- Galvanized post brackets are required to connect all posts to concrete piers.
- Decks over 30" high require railings; minimum railing height is 36".
- Stairs with 4 or more risers, shall have handrails & guardrails to enclose the stairway.
NO OPEN STAIR RISERS PERMITTED.
- Railing posts shall be mounted inside of rim joists and blocked for stability.
- Joist spans over 8' require solid blocking. Blocking shall be a minimum of 60% of the joist height.
- Additional regulations may be required depending on the specific project design.



Village of Mount Prospect
 Community Development Department
 50 S. Emerson Street
 Mount Prospect, Illinois 60056
 Phone: (847) 870-5675

Email: building@mountprospect.org

Deck Supplement

MAXIMUM JOIST SPACING (ON CENTER)


DECKING MATERIAL	PERPENDICULAR TO JOIST	DIAGONAL TO JOIST
1-1/4" THICK WOOD	16" O.C.	12" O.C.
2" THICK WOOD	24" O.C.	16" O.C.
COMPOSITE	PER MANUFACTURER'S SPECIFICATIONS	

TYPICAL MAXIMUM JOIST SPAN FOR WOOD DECKS

JOIST SIZE	NO CANTILEVER			WITH CANTILEVER (MAX. 2'-0")		
	12" O.C.	16" O.C.	24" O.C.	12" O.C.	16" O.C.	24" O.C.
2 X 6	8'-10"	8'-0"	7'-0"	5'-7"	5'-7"	5'-7"
2 X 8	11'-8"	10'-7"	8'-8"	8'-6"	8'-6"	8'-6"
2 X 10	14'-11"	13'-0"	10'-7"	12'-3"	12'-3"	10'-7"
2 X 12	17'-5"	15'-1"	12'-4"	16'-5"	15'-1"	12'-4"

TYPICAL DECK BEAM SPANS

		SPAN OF JOISTS BEARING ON BEAM						
		6'	8'	10'	12'	14'	16'	18'
DOUBLE	BEAM SIZE							
	(2) 2 X 6	5'-5"	4'-8"	4'-2"	3'-10"	3'-6"	3'-1"	2'-9"
	(2) 2 X 8	6'-10"	5'-11"	5'-4"	4'-10"	4'-6"	4'-1"	3'-8"
	(2) 2 X 10	8'-4"	7'-3"	6'-6"	5'-11"	5'-6"	5'-1"	4'-8"
TRIPLE	(2) 2 X 12	9'-8"	8'-5"	7'-6"	6'-10"	6'-4"	5'-11"	5'-7"
	(3) 2 X 6	7'-4"	6'-8"	6'-0"	5'-6"	5'-1"	4'-9"	4'-6"
	(3) 2 X 8	9'-8"	8'-6"	7'-7"	6'-11"	6'-5"	6'-0"	5'-8"
	(3) 2 X 10	12'-0"	10'-5"	9'-4"	8'-6"	7'-10"	7'-4"	6'-11"
	(3) 2 X 12	13'-11"	12'-1"	10'-9"	9'-10"	9'-1"	8'-6"	8'-1"





Village of Mount Prospect
 Community Development Department
 50 S. Emerson Street
 Mount Prospect, Illinois 60056
 Phone: (847) 870-5675


Email: building@mountprospect.org

Deck Supplement


CONCRETE PIER SIZING TABLE

PIER SIZE	BEARING AREA	BEARING CAPACITY*	MAX. TRIBUTARY AREA (XxY)
10" DIAMETER	0.545 SQ.FT.	1,363 LBS	27 SQ.FT. (5'x5')
12" DIAMETER	0.785 SQ.FT.	1,962 LBS	39 SQ.FT. (6'x6')
14" DIAMETER	1.068 SQ.FT.	2,670 LBS	53 SQ.FT. (7'x7')
16" DIAMETER	1.395 SQ.FT.	3,488 LBS	70 SQ.FT. (8'x8')
18" DIAMETER	1.766 SQ.FT.	4,415 LBS	88 SQ.FT. (9'x9')

* BEARING CAPACITY BASED ON ASSUMED 2,500 PSF SOIL



POST BEAM BEARING DETAILS






Village of Mount Prospect
 Community Development Department
 50 S. Emerson Street
 Mount Prospect, Illinois 60056
 Phone: (847) 870-5675

Email: building@mountprospect.org


Deck Supplement

DECK LEDGER CONNECTION

CONNECTION TYPE	JOIST SPAN BEARING ON LEDGER						
	UNDER 6'	6' - 8'	8' - 10'	10' - 12'	12' - 14'	14' - 16'	16' - 18'
1/2" DIA. LAG SCREW	30	23	18	15	13	11	10
1/2" DIA. LAG BOLT	36	36	34	29	24	21	19
1/2" DIA. THRU-BOLT WITH SHEATHING OVER 1/2", BUT LESS THAN 1" THICK	36	36	29	24	21	18	16



LEDGER CONNECTION LOCATIONS



LEDGER CONNECTION AND HOLD DOWN DEVICE DETAILS